



Tuesday, December 10, 2013

Buddy Mitchell
1138 Pleasant Ridge Rd
Greensboro, NC 27409

Ref: Malfunctioning septic system serving 1138 Pleasant Ridge Rd

Dear Mr. Mitchell

On November 25, 2013 I visited your property to evaluate the malfunctioning septic system serving your home at the above referenced address. Upon evaluation, it appears a sludge or root blocked line is causing problems with the distribution of your septic system resulting in the plumbing in the home to back up and/or drain slow. Due to the proximity of the property to a public sanitary sewer line, the best option for a permanent solution to the issues being experienced with your septic system is connection to this public sewer line.

If you have any questions, please feel free to call me at any time at (336) 641-3628.

Sincerely,

A handwritten signature in black ink that reads "K. Joe Johnson REHS, LSS". The signature is written in a cursive style.

K. Joe Johnson, REHS, LSS
Environmental Health Program Specialist