



Public Health Division

June 28, 2016

Cathy Justice, Community Relations Specialist  
Legislative Department  
City of Greensboro  
Phone: 336-373-2723; Fax: 336-373-4656  
PO Box 3136, Greensboro, NC 27402-3136  
[www.greensboro-nc.gov](http://www.greensboro-nc.gov)

Cathy,

After reviewing the property at 3315 Sandy Ridge Rd, it is unlikely that a septic repair can be installed that will serve the property for a reasonable period of time due to lack of available space and areas of compacted soils. For this reason, it is necessary for the home to be connected to Greensboro sewer.

Thanks,  
K. Joe Johnson REHS, LSS  
Environmental Health Program Specialist  
NC Licensed Soil Scientist  
400 W. Market St.  
Greensboro, NC 27401  
Office: 336-641-3628  
Cell: 336-451-7337