



## Legislation Details (With Text)

<b>File #:</b>	ID 19-0026	<b>Version:</b>	1	<b>Name:</b>	Envirocare Sole Source
<b>Type:</b>	Resolution	<b>Status:</b>	Passed		
<b>File created:</b>	12/28/2018	<b>In control:</b>	City Council		
<b>On agenda:</b>	1/15/2019	<b>Final action:</b>	1/15/2019		
<b>Title:</b>	Resolution Authorizing the Sole Source Purchase of an EnviroCare International, Inc. VenturiPak Wet Scrubbing Emission Control System in the Amount of \$380,950 for the T.Z. Osborne Water Reclamation Facility				
<b>Sponsors:</b>					
<b>Indexes:</b>	District 2, WR Contracts				
<b>Code sections:</b>					
<b>Attachments:</b>	1. 4083P75 Rev.1 TZO.pdf, 2. MWBE Memo_EnviroCare Wet Scrubbing Emission Control System1.pdf, 3. 19-0026 Sole Source Envirocare.pdf				

Date	Ver.	Action By	Action	Result
1/15/2019	1	City Council	adopt	Pass

Resolution Authorizing the Sole Source Purchase of an EnviroCare International, Inc. VenturiPak Wet Scrubbing Emission Control System in the Amount of \$380,950 for the T.Z. Osborne Water Reclamation Facility

Department: Water Resources  
Council District: 2

Public Hearing: N/A  
Advertising Date/By: N/A

Contact 1 and Phone: Steven Drew, 336-373-7893  
Contact 2 and Phone: Elijah Williams, 336-373-4632

### PURPOSE:

Water Resources requests approval to sole source the purchase of a wet scrubbing emission control system from EnviroCare International, Inc. located in American Canyon, California. City Council approval is required to sole source a purchase under State Public Contracting Statute GS 143-129 (e)(6) which allows exceptions to the letting of public contracts for the purchase of apparatus, supplies, materials or equipment when standardization or compatibility is the overriding consideration. In this particular case the sole source option was chosen because the existing wet scrubber can be readily replaced in order to update the existing structure.

### BACKGROUND:

The existing foul air scrubber system was installed in 1994 and is currently presenting challenges in meeting the removal limits of the MACT (Maximum Achievable Control Technology) standards enacted in 2015 and is also creating operational challenges in removing biosolids from the plant including higher pressures and temperatures. An evaluation performed in 2017/2018 addressed the existing system's performance and the Water Resources Department determined the most cost effective option would be to replace the aging scrubber

equipment with a modification to the existing EnviroCare Tray Scrubber unit with a new VenturiPak system manufactured by EnviroCare. This is a proven technology used for this purpose on other sewage sludge incinerators (SSI) in the wastewater industry. The modification to the EnviroCare system will result in full operation of the SSI and achievement of full regulatory compliance with the MACT Standards. The City's design engineer has reviewed the quote to ensure the quoted system meets the required design and performance specifications, and is quoted at a fair and reasonable cost.

**BUDGET IMPACT:**

Funding is budgeted in Water Resources Operating Fund account 501-7056-01.6059 in the amount of \$380,950. A budget adjustment is needed to use this account.

**RECOMMENDATION / ACTION REQUESTED:**

The Water Resources Department recommends and requests that City Council approve the sole source purchase of a wet scrubbing emission control system from EnviroCare in the amount of \$380,950.